# •Zennio

4-channel constant voltage PWM dimmer in DIN rail for DC LED loads

#### ZDILDX4V2

### **FEATURES**

- 4 constant voltage configurable channels (combinable independent channels, RGBW channel, RGB+W channels and combinable TW channels)
- 1 relay to control the LEDs power supply or for independent use
- Supports KNX Data Secure
- Master Light control
- External 12-40 VDC power supply
- Manual output operation with push button and LED status indicator
- Total data saving on KNX bus failure
- Integrated KNX BCU (TP1-256)
- Dimensions 67 x 90 x 79 mm (4.5 DIN units)
- DIN rail mounting according to IEC 60715 TH35, with fixing clamp
- Conformity with the CE, UKCA, RCM directives (marks on the right side)

# TECHNICAL DOCUMENTATION

Lumento DX4 v2



Figure 1: Lumento DX4 v2

1. Power Supply LED	2. Colour shift control buttons	3. External power supply	4. Colour output LEDs	5. TW selection button
6. (not used)	7. Relay status LED	8. Relay control button	9. Power Supply Relay	10. Output channels
11. KNX connector	12. Programming/Test LED	13. Programming/Test button	14. Channel status LED	15. Channel control button

Programming/Test button: short press to set programming mode. If this button is held while plugging the device into the KNX bus, it enters the safe mode. If this button is held for more than 3 seconds, the device enters the test mode. In order to perform a KNX Secure factory reset, while the device is in safe mode, press the button for 10 seconds until the programming LED changes its state.

Programming/Test LED: programming mode indicator (red). When the device enters the safe mode, it blinks (red) every half second. The test mode is indicated by the green color. During the start-up (reset or after KNX bus failure) and if the device is not in safe mode, it emits a red flash.

GENERAL SPECIFICATIONS					
CONCEPT		DESCRIPTION			
Type of device	Type of device		Electric operation control device	Electric operation control device	
	Voltage (typical)		29 VDC SELV	29 VDC SELV	
	Voltage range		21-31 VDC		
	Maximum consumption	Voltage	mA	mW	
KNX supply		29 VDC (typical)	6.2	179.2	
	consumption	24 VDC <sup>1</sup>	10	240	
	Connection type			Typical TP1 bus connector for 0.8 mm Ø rigid cable	
External powe	er supply		12-40 VDC	12-40 VDC	
Operation terr	nperature		0 +55 °C		
Storage temp			-20 +55 °C	-20 +55 °C	
Operation hur	nidity		5 95%	5 95%	
Storage humidity		595%			
Complementa	ary characteristic	S	Class B	Class B	
Protection class / Overvoltage category		II / III (4000 V)	II / III (4000 V)		
Operation typ	Operation type		Continuous operation	Continuous operation	
Device action type		Туре 1			
Electrical stress period		Long			
Degree of protection		IP20, clean environment			
Installation		Independent device to be mounted	Independent device to be mounted inside electrical panels with DIN rail (IEC		
		60715)			
	Minimum clearances		Not required		
Response on KNX bus failure		Data saving according to parameterization			
Response on KNX bus restart		Data recovery according to parameterization			
Operation indicator		The programming LED indicates programming mode (red) and test mode			
		(green). Color shift LEDs show the current color. Each output LED indicates			
		its status.			
Weight		200 g			
PCB CTI index		175 V			
Housing material		PC FR V0 halogen free	PC FR V0 halogen free		

Housing material PC FR vo halogen i

<sup>1</sup> Maximum consumption in the worst-case scenario (KNX Fan-In model).

OUTPUTS SPECIFICATIONS AND CONNECTIONS		
CONCEPT	DESCRIPTION	
Number of outputs	4	
Output type / Disconnection type	Solid state switching device	
Maximum load per output	10 A	
Total maximum current in device	24 A	
Load type	LED strip (monochrome, RGB, RGBW or TW) with common anode (+)	
Short-circuit protection	YES	
Overheating protection	YES	
Connection method	Screw terminal block (0.5 Nm max.)	
Cable cross-section	1.5-4 mm <sup>2</sup> (IEC) / 26-10 AWG (UL)	
* In case of channel parallel parameterization, these outputs must be wire connected		

In case of channel parallel parameterization, these outputs must be wire-connected.

EXTERNAL POWER CONNECTIONS	SUPPLY SPECIFICATIONS AND
CONCEPT	DESCRIPTION
Voltage	12-40 VDC (voltage in concordance with voltage LED strips to be connected)
Current	Depending upon the load to be controlled up to a maximum of 24 A
Connection method	Screw terminal block (0.5 Nm max.)
Cable cross-section	1.5-4 mm <sup>2</sup> (IEC) / 26-10 AWG (UL)

RELAY SPECIFICATIONS AND CONNECTIONS				
CONCEPT		DESCRIPTION		
Number of outputs		1		
Output type / Disconnection type		Potential-free outputs through bistable relays with tungsten pre-contact / Micro-disconnection		
Relay rated current		AC 16(6) A @ 250 VAC (4000 VA) DC 7 A @ 30 VDC (210 W)		
Maximum load	Resistive	4000 W		
per output	Inductive	1500 VA		
Maximum inrush current		800 A/200 μs		
		165 A/20 ms		
Short-circuit protection		NO		
Overload protection		NO		
Connection method		Screw terminal block (0.5 Nm max.)		
Cable cross-section		1.5-4 mm <sup>2</sup> (IEC) / 26-10 AWG (UL)		
Maximum response time		10 ms		
Mechanical lifetime (min. cycles)		3 000 000		
Electrical lifetime (min. cycles)		100000 @ 8 A / 25000 @ 16 A (VAC)		

#### WIRING DIAGRAMS



#### INDEPENDENT CHANNELS



#### \*PARALLEL CHANNELS



**NOTE:** The  $\oplus$  pole of each channel in use must be mandatorily connected.



TW CHANNELS

#### POWER SUPPLY RELAY



#### Attaching Lumento DX4 v2 to DIN rail:



Removing Lumento DX4 v2 from DIN rail:



Power supply Overheating Short-circuit failure Channel status LED 0 s 0.5s 1.0 s 1.5 s 2.0 s 2.5 s (s) 3.0 s time 3.5 s 4.0 s 4.5 s 5.0 s 5.5 s 6.0 s Power Out LED

Figure 2: Error notification LED codes

## SAFETY INSTRUCTIONS AND ADDITIONAL NOTES

- Installation should only be performed by qualified professionals according to the laws and regulations applicable in each country.
- Do not connect the mains voltage nor any other external voltage to any point of the KNX bus; it would represent a risk for the entire KNX system. The facility must have enough insulation between the mains (or auxiliary) voltage and the KNX bus or the wires of other accessories, in case of being installed.
- The facility must be equipped with a device that ensures the omnipolar sectioning. Installation of a 10 A mini-circuit-breaker is recommended. To prevent accidents, it must remain open in case of manipulation of the device.
- Once the device is installed (in the panel or box), it must not be accessible from outside.
- Keep the device away from water (condensation over the device included) and do not cover it with clothes, paper or any other material / while in use.
- The WEEE logo means that this device contains electronic parts and it must be properly disposed of by following the instructions at https://www.zennio.com/en/legal/weee-regulation.

This device contains software subject to specific licences. For details, please refer to https://zennio.com/licenses.